



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA200591

Date of Issue: 17 March 2021

Regulatory Definition: Non-Prescribed

Product Description: Grid-tied photovoltaic Inverter

General Modification:

Use of alternative contravariant inductance.

Additional Models	Trade Name	Rating/Marking
GW2500N-XS	GOODWE	Input: MPPT Voltage range: 50-550Vdc, Max 600Vdc, Max 13A, Isc PV: 16.3A Output: 200/230V~ 50/60Hz, Max 12A, 2500W Rated apparent power: 2500VA ta: 60°C, Class I, IP65
GW3000N-XS	GOODWE	Input: MPPT Voltage range: 50-550Vdc, Max 600Vdc, Max 13A, Isc PV: 16.3A Output: 200/230V~ 50/60Hz, Max 14.3A, 3000W Rated apparent power: 3000VA ta: 60°C, Class I, IP65

R.A. Hill


For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and RECS accreditation under the Queensland Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 17-03-21 200591/4